





MODEL TR-32-2
FORWARD AND REVERSE
DIGITAL INDICATOR - TOTALIZER - TRANSMITTER
FOR TWO DIRECTIONAL FLOW
CURRENT OUTPUT
ONE PULSE PER TOTALIZER COUNT



TYPICAL FORWARD
DIGITAL INDICATOR-TOTALIZER



TYPICAL REVERSE
DIGITAL INDICATOR-TOTALIZER

MADC OUTPUT

4-20 mA @ _____
 Red (+)
 Green (-)
 Shield to ground
PULSE OUTPUT
 One pulse per count
 White (+) Black (-)
 Shield to ground



DESCRIPTION

MODEL TR-32-2 INDICATOR-TOTALIZER-TRANSMITTERS provide a digital flow rate indication, a totalization of flow volume, a 4-20mA current signal proportional to the rate of flow, and scaled output when mounted on our electronic propeller meters. The unit features a digital indicator-totalizer and solid state construction transmitter.

INSTALLATION is normally made at the factory to the special forward and reverse flow meter tube, but installation may be made in the field by removing the existing meter head and attaching the electronic forward and reverse digital indicator-totalizer meter head assembly to the meter. Model TR-32-2 is for installation on propeller meters. The unit is furnished complete ready for installation. An optional kit of adapters, with up to 100 feet of cable, is available to locate a TR-32-2 at a remote location.

CONSTRUCTION of the unit features a sealed housing conforming to NEMA 4X standards which has a padlock hasp. It uses the latest solid state components, and is completely encapsulated to protect it from moisture. The TR-32-2 is driven by a solid state sensor producing 8 pulses per revolution of the propeller. The unit can be mounted in four different directions for the easiest possible reading.

DIGITAL INDICATOR-TOTALIZER has a non-volatile EEPROM memory to store totalizer count (updated every 60 minutes while running). The indicator-totalizer will continue to function, even if the 24 VDC loop power is lost, or during battery changing. (If the 24 VDC power is lost, the battery backup will power the display, but the 4-20mA will not be available.) The indicator dial can be furnished in GPM, CFS, MGD or any standard liquid measuring units with a choice of totalizer measuring units. The display is programmable to update from 0.5 to 5 seconds, and timeout from 1 to 9999 seconds.

INDICATOR (rate) FUNCTION is a five digit indicator with .35" tall numbers, programmable with 0 to 4 decimal places with 0.0001 to 9999 rate scaling factor. The calculation method is 1/Tau; programmable smoothing of 0 to 99%; rate zero time of 8 seconds.


TOTALIZER FUNCTION is an eight digit indicator with .20" tall numbers, programmable with 0 to 4 decimal places, and a total scaling factor of 0.0001 to 9999. The totalizer can be reset from the front panel or permanently disabled.

TRANSMITTER is driven by the same sensor output as the digital indicator-totalizer. The standard 4-20mA current output gives 4 mA output at zero flow and 20 mA output at maximum scale range. A 24 VDC power supply in series is required to power the mA output. The transmitter will drive up to a maximum of 600 ohms of loop resistance. The standard output is an open collector type. A four lead shielded cable, four feet long, is furnished with each transmitter. The transmitter pulse output will operate a Water Specialties Model IN-16 LCD totalizer up to 1,000 feet away.

SPECIFICATIONS

ACCURACY	Rate	$\pm 0.25\%$ of reading.	
TEMPERATURE RANGE	Operation: Storage:	32° to 160° F. -40° to 160° F.	
	Consult factory for special construction for other temperatures.		
INPUT SIGNAL	Type Voltage Range Minimum Frequency Maximum Frequency Minimum Pulse Width	Voltage pulse. 1 to 10V. 0.125Hz. 3KHz. 2 μ s.	
OUTPUT SIGNALS	Combination 4-20mA Output and Isolated Scaled Pulse Output: Standard 2 wire loop powered. 16 bits resolution. Operating voltage Power Switch	12 to 32VDC. Automatic battery override.	
		Scaled Pulse Output: Open collector MOS transistor. Pulse width Maximum Rating	32 milliseconds. 1 to 32 V.
EMI/EMC	Electrostatic Discharge (IEC 1000-4-2 Level 3). Electrical Fast Transient (IEC 1000-4-4 Level 3). RF Susceptibility	8KV 1KV 150 KHz to 230 MHz @ 10V (IEC 1000-4-4 Level 3).	
POWER SUPPLY	24VDC (as supplied by our power supply Model IN-36-1, available separately) wired in series. Indicator-totalizer-transmitter is primarily loop powered, but becomes self-powered via a lithium battery in the event of a power loss. Battery Type - 3VDC Lithium, Replaceable Operating Life - 4 years (when used with the display timeout into sleep mode feature). Low Battery Indication - 6 months before expiration.		
OPTIONAL EQUIPMENT	Mounting brackets, with up to 100 feet of cable for remote installation.		
SHIPPING WEIGHT	12 pounds.		
ORDERING INFO	Must be specified by the customer and includes: Serial number of meter unit is to be mounted on. Maximum scale range required for 4-20 output. Indicator scale and units. Totalizer dial units. Consult factory for special applications.		

MODEL TR-32-2
 FORWARD AND REVERSE
 DIGITAL INDICATOR - TOTALIZER - TRANSMITTER
 FOR TWO DIRECTIONAL FLOW
 CURRENT OUTPUT
 ONE PULSE PER TOTALIZER COUNT



Power Supply	Power Supply Voltage for Loop	Maximum Resistance of Instruments in Loop
Variable	15.0VDC	150Ω
Variable	18.0VDC	300Ω
Variable	21.0VDC	450Ω
IN-36-1(24V)	24.0VDC	600Ω
Variable	27.0VDC	750Ω
Variable	30.0VDC	900Ω

NOTES:

The transmitter will drive up to a maximum of 600 ohms loop resistance.

Wire Size Information:

The distance of the communication line from transmitter to the device the 4-20mA will operate depends on the loop resistance, the wire size, and the power supply. Based on a 24V DC power supply and 22 gauge wire, we recommend a maximum loop of 3,500 feet.



Visit our Website: www.mccrometer.com
 E-Mail: info@mccrometer.com

3255 WEST STETSON AVENUE • HEMET, CALIFORNIA 92545-7799 USA
 TEL: 909-652-6811 • FAX: 909-652-3078

Copyright © 2002 McCrometer. All printed material should not be changed or altered without permission of McCrometer. The published technical data and instructions are subject to change without notice. Contact your McCrometer representative for current technical data and instructions.